


Fan Relay Termination

DWG. TERM.	NTE TERM.	WHITE ROGERS TERM.
A	1	1
B	2	3
C	3	2
D	4	4

NTE Part: R47-1A15-120
White Rogers Part: 90-291Q



View looking at wire entry side.

CON2 9-Pin Connector

Pin	Color	Function	CM2-OEM-XX Element
1	Gray/Black	Interlock Source (High Limit/Fume Switch)	K1
1	Yellow	Furnace Auger Motor	---
2	Orange	Power Vent Motor (if required)	K9
3	White	Neutral	
4		NC	
5	White	Neutral	
6	Green	Ground	
7	Red	Bin Auger Motor	K3
8	Gray	Interlock Return (High Limit/Fume switch)	
9	Blue	Combustion Motor	K7

NOTES

- 1) If Power vent is used, Fume switch is required.
- 2) Remove if Powervent is used.
- 3) Install if Powervent is used.
- 4) All connector designations are CON2 unless noted.

CONFIDENTIAL

CONTROL FOR LMF CORN FURNACE		
12/12/13	REV 11	NJW
12/13/12	REV 10	
10/17/07	REV 1	

