



Connection on Circulation Pump Limit
Yellow Wire should be connected to B
terminal Not to W Terminal.

Wire Color Code	
BK	= Black
HTBK	= High Temp Black
O	= Orange
B	= Blue
Y	= Yellow
R	= Red

White Wire Needs
To Be Connected
TO #7 on Timer Socket
And Wire Capped With
White Wires.

Remove Jumper wire
that connects 1 & 2
Terminals. (If Attached)

Boiler Control Box